



SCENARIO: ACCESS CONTROL SYSTEM HAS A RELAY OUTPUT THAT HOLDS FOR 2 MINUTES.  
YOU DON'T WANT ACTIVATION TO OCCUR UNTIL AFTER RELAY RELEASES.

- NOTES:**
- 1) SET BR-3 TO FUNCTION 25
  - 2) SET TIMERS AS FOLLOWS
  - H1= 01
  - H2= 02
  - DI= \_1 (.25 SEC.)

100 ENTERPRISE DRIVE  
PITTSBURGH, PA 15275  
PHONE: (412) 249-4100  
FAX: (412) 249-4101  
EMAIL: [www.beasensors.com](http://www.beasensors.com)

**TITLE: BR3 DELAYED ACTIVATION  
ON BREAK**

SIZE:	DRAWN BY:	REV BY:	PART NO:
<b>A</b>	wjr		<b>80.0366</b>
	SCALE:	DATE:	SHEET
	NONE	October 24, 2014	1 OF 1

